



HEALTHY AND SAFE SCHOOLS PLAN

OR 581-022-2223 requires school districts to develop a Healthy and Safe Schools Plan. The four areas covered by Bethel School District's Healthy and Safe Schools Plan are Radon, Lead in Drinking Water, Lead Paint, and Integrated Pest Management.

Responsible Person

OR 581-022-2223(5)(a) states that the Healthy and Safe Schools Plan must include the position within the school district's or public charter school's administration responsible for maintaining and implementing the Healthy and Safe Schools Plan.

The person responsible for maintaining and implementing the Healthy and Safe Schools Plan in Bethel School District is:

Jason Betterley
Facilities Supervisor
jason.betterley@bethel.k12.or.us
541-689-7693

List of Buildings

OR 581-022-2223(5)(b) states that the Healthy and Safe Schools Plan must include a list of all facilities that are included in the Healthy and Safe Schools Plan.

The Bethel Healthy and Safe School Plan covers the following buildings:

Clear Lake Elementary	4646 Barger Drive	541-689-0511
Danebo Elementary	1265 Candlelight Drive	541-688-8735
Fairfield Elementary	3455 Royal Avenue	541-689-3751
Irving Elementary	3200 Hyacinth	541-688-2620
Malabon Elementary	1380 Taney Street	541-461-6421
Meadow View School	1855 Legacy Street	541-607-9700
Prairie Mountain School	5305 Royal Avenue	541-607-9849
Cascade Middle School	1525 Echo Hollow Road	541-689-0641
Shasta Middle School	4656 Barger Drive	541-688-9611
Kalapuya High School	1200 North Terry Street	541-607-9853
Willamette High School	1801 Echo Hollow Road	541-689-0731
Print Shop/Transportation	1730 Taney Street	541-607-6428
Bethel Administration	4640 Barger Drive	541-689-3280

Radon

Bethel School District has developed a plan to accurately measure school buildings for elevated radon levels. See the complete plan here: <http://www.bethel.k12.or.us/radon/>

Lead in Drinking Water

Bethel School District has developed a plan to test for and reduce exposure to lead in water used for drinking or food preparation. Any and all lead testing of drinking water will be conducted by an Oregon Health Authority accredited lab.

Bethel School District proactively began testing for lead in drinking water in June 2016. Nearly 850 potential sources were tested in every Bethel School District facility.

See the complete results here: <http://www.bethel.k12.or.us/lead-in-drinking-water/>

In order to ensure safe water for drinking or food preparation in all District facilities, the Bethel Healthy and Safe Schools Plan identifies this course of action:

1. **Identifying sources of lead:** The District will follow the Environmental Protection Agency's 3 T's Revised Technical Guidance to ensure that samples for lead are collected properly and from the appropriate locations. An OHA-accredited drinking water laboratory will be used for the analysis of the samples. All water sources used for drinking or food preparation will be tested every 10 years, at a minimum. At each building location, 10% of potable sources will be sampled. If any initial results are found elevated, the remaining potable sources will be sampled from that building location.
2. **Stop access:** All water taps that have more than 20 parts per billion (ppb) of lead will be immediately shut off and covered or otherwise labeled as not to be used until the source of the lead is identified, repaired, and tested. If necessary, bottled water will be provided to students and staff members until the source of the lead is determined and addressed.
3. **Communicate:** Results from tests for lead in District water sources will be made available to students, families, and the community as quickly as possible. This will be done through email and/or the District website.
4. **Mitigate and correct:** The sources of lead in building plumbing will be replaced as soon as possible. Follow-up tests will be conducted with the results shared with students, families and the community. Again, EPA 3T's Guidance will be followed. The EPA's 3Ts technical guidance is available at: https://www.epa.gov/sites/production/files/2018-09/documents/final_revised_3ts_manual_508.pdf

Lead Paint

In order to reduce exposure to lead paint in Bethel School District facilities, the district will comply with the United States Environmental Protection Agency's Renovation, Repair and Painting Program Rule 3

requiring that individuals and firms conducting renovation on child-occupied facilities (child care and schools) be certified to follow lead-safe work practices.

The EPS's Small Entity Compliance Guide to Renovate Right is available here: [Small Entity Compliance Guide to Renovate Right](https://www.epa.gov/sites/production/files/documents/sbcomplianceguide.pdf) <https://www.epa.gov/sites/production/files/documents/sbcomplianceguide.pdf>

Integrated Pest Management

The district has adopted an integrated pest management plan as required by ORS 634.700 through 634.750. A copy of the IPM plan and its operational guidelines are available on the district website as [District Policy and Administrative Rule EEA](http://163.41.16.10/policies/EEA%20P.pdf) <http://163.41.16.10/policies/EEA%20P.pdf> and it is available here: [Integrated Pest Management Plan](http://www.bethel.k12.or.us/integrated-pest-management/) <http://www.bethel.k12.or.us/integrated-pest-management/>

Communication

Bethel School District will publicly share the results for all tests required under the Healthy and Safe Schools Plan within five business days of receiving the results. The test results will be posted on the district website and shared with the community via email and social media. In addition, hard copies and an explanation of the tests and results will be made available at the district office.