

Water Testing Results - Bethel Farm

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
	20880800-001BF	2/23/2021	0.202
	20880800-002OS	2/23/2021	0.302
	20880800-003DW	2/23/2021	ND
	20880800-004DW	2/23/2021	ND
	20880800-005OT	2/23/2021	1.22
	20880800-006KF	2/23/2021	0.307
	20880800-007KF	2/23/2021	ND
	20880800-008KF	2/23/2021	ND
	20880800-009KF	2/23/2021	ND

ND = Non Detect - Lead level is below the set detection limits of **.2** ppb

Lab Sheets reporting in ug/L *** ug/L = ppb